


Отчет (акт) о потреблении тепловой энергии и теплоносителя за период с 16.09.2021 по 22.10.2021

Потребитель: "ООО ""ЖКС № 2 НЕВСКОГО РАЙОНА""
 Адрес: КАРАВАЕВСКАЯ УЛ, Д.38[2]
 Договор: 31502

Тип прибора:
 Номер прибора: ВКТ-7-04
 Схема измерения: 225926
 СИ-1

| Дата | НС, # | п, ч | M1, т | t1, гр.С | P1, кгс/см2 | M2, т | t2, гр.С | P2, кгс/см2 | t1-t2, гр.С | M1-M2, т | Wсумм, Гкал | Линия ГВС, # |
|--|-------|------|----------|----------|-------------|----------|----------|-------------|-------------|----------|-------------|--------------|
| 16.09.2021 | | 24 | 40.23 | 69.8 | 8.8 | 39.92 | 34 | 7 | 35.7 | 0.31 | 1.448 | 1.448 |
| 17.09.2021 | | 24 | 143.88 | 54.2 | 8.8 | 143.87 | 36.6 | 7 | 17.7 | 0.01 | 2.541 | 2.541 |
| 18.09.2021 | | 24 | 177.14 | 47.8 | 8.8 | 177.14 | 35.5 | 7 | 12.4 | 0 | 2.193 | 2.193 |
| 19.09.2021 | | 24 | 166.57 | 49.4 | 8.8 | 166.02 | 35.7 | 7 | 13.6 | 0.55 | 2.292 | 2.292 |
| 20.09.2021 | | 24 | 174.08 | 48.8 | 8.8 | 172.65 | 35.6 | 7 | 13.3 | 1.43 | 2.359 | 2.359 |
| 21.09.2021 | | 24 | 190.64 | 46.2 | 8.8 | 187.32 | 34.7 | 7 | 11.6 | 3.32 | 2.317 | 2.317 |
| 22.09.2021 | | 24 | 180.11 | 45.6 | 8 | 180.18 | 34.1 | 6.4 | 11.5 | -0.07 | 2.069 | 2.069 |
| 23.09.2021 | | 24 | 86.69 | 56 | 4.2 | 86.13 | 39.8 | 3.4 | 16.3 | 0.56 | 1.434 | 1.434 |
| 24.09.2021 | | 24 | 41.64 | 57.7 | 2.7 | 37.43 | 40.6 | 2.4 | 17.1 | 4.21 | 0.883 | 0.883 |
| 25.09.2021 | | 24 | 181.12 | 55.8 | 8.7 | 180.57 | 39.6 | 7.2 | 16.2 | 0.55 | 2.965 | 2.965 |
| 26.09.2021 | | 24 | 183.88 | 43.1 | 8.4 | 184.14 | 33.6 | 6.7 | 9.5 | -0.26 | 1.736 | 1.736 |
| 27.09.2021 | | 24 | 190.76 | 49 | 8.3 | 190.91 | 36.2 | 6.5 | 12.8 | -0.15 | 2.427 | 2.427 |
| 28.09.2021 | | 24 | 191.59 | 53.2 | 8.5 | 190.43 | 38.8 | 6.7 | 14.5 | 1.16 | 2.819 | 2.819 |
| 29.09.2021 | | 24 | 190.95 | 53.3 | 8.6 | 190.8 | 38.8 | 6.8 | 14.5 | 0.15 | 2.773 | 2.773 |
| 30.09.2021 | | 24 | 195.77 | 53.3 | 8.6 | 195.69 | 39 | 6.8 | 14.3 | 0.08 | 2.801 | 2.801 |
| 01.10.2021 | | 24 | 202.06 | 53.3 | 8.7 | 201.8 | 39.3 | 6.7 | 14 | 0.26 | 2.835 | 2.835 |
| 02.10.2021 | | 24 | 200.86 | 53.3 | 8.7 | 199.93 | 39.5 | 6.7 | 13.8 | 0.93 | 2.807 | 2.807 |
| 03.10.2021 | | 24 | 199.31 | 53.2 | 8.7 | 197.69 | 39.3 | 6.8 | 14 | 1.62 | 2.852 | 2.852 |
| 04.10.2021 | | 24 | 198.35 | 53.2 | 8.7 | 196.02 | 39 | 6.8 | 14.2 | 2.33 | 2.917 | 2.917 |
| 05.10.2021 | | 24 | 198.15 | 53.2 | 8.7 | 196.03 | 38.9 | 6.8 | 14.3 | 2.12 | 2.92 | 2.92 |
| 06.10.2021 | | 24 | 201.13 | 53.2 | 8.7 | 198.94 | 39.2 | 6.8 | 14 | 2.19 | 2.91 | 2.91 |
| 07.10.2021 | | 24 | 199.38 | 53.3 | 8.7 | 197.84 | 39.2 | 6.8 | 14.1 | 1.54 | 2.87 | 2.87 |
| 08.10.2021 | | 24 | 193.95 | 53.3 | 8.7 | 193.38 | 39 | 6.9 | 14.3 | 0.57 | 2.79 | 2.79 |
| 09.10.2021 | | 24 | 214.39 | 40.2 | 8.3 | 214.25 | 32.7 | 6 | 7.5 | 0.14 | 1.619 | 1.619 |
| 10.10.2021 | | 24 | 209.52 | 45 | 8.4 | 210.53 | 34.3 | 6.3 | 10.7 | -1.01 | 2.211 | 2.211 |
| 11.10.2021 | | 24 | 195.04 | 43 | 8.1 | 195.43 | 34 | 6.2 | 9 | -0.39 | 1.744 | 1.744 |
| 12.10.2021 | | 24 | 197.89 | 53.5 | 8.4 | 197.89 | 38.5 | 6.4 | 15 | 0 | 2.968 | 2.968 |
| 13.10.2021 | | 24 | 203.69 | 44.4 | 8.5 | 204.23 | 34.4 | 6.4 | 10 | -0.54 | 2.014 | 2.014 |
| 14.10.2021 | | 24 | 204.03 | 47.4 | 8.5 | 204.3 | 35.4 | 6.4 | 12 | -0.27 | 2.449 | 2.449 |
| 15.10.2021 | | 24 | 192.57 | 56 | 8.7 | 192.57 | 39.4 | 6.9 | 16.6 | 0 | 3.199 | 3.199 |
| 16.10.2021 | | 24 | 189.15 | 56.2 | 8.7 | 189.15 | 39.6 | 7 | 16.6 | 0 | 3.14 | 3.14 |
| 17.10.2021 | | 24 | 188.14 | 55.7 | 8.7 | 188.13 | 39.2 | 7 | 16.4 | 0.01 | 3.088 | 3.088 |
| 18.10.2021 | | 24 | 186.1 | 54.8 | 8.7 | 185.85 | 38.6 | 7 | 16.2 | 0.25 | 3.034 | 3.034 |
| 19.10.2021 | | 24 | 189.15 | 53.8 | 8.6 | 188.17 | 37.9 | 6.9 | 15.8 | 0.98 | 3.035 | 3.035 |
| 20.10.2021 | | 24 | 196.57 | 55.2 | 8.6 | 194.94 | 38.7 | 6.7 | 16.4 | 1.63 | 3.297 | 3.297 |
| 21.10.2021 | | 24 | 203.27 | 53.2 | 8.7 | 201.56 | 38.8 | 6.7 | 14.4 | 1.71 | 2.995 | 2.995 |
| 22.10.2021 | | 24 | 201.58 | 57.5 | 8.7 | 199.75 | 40.8 | 6.7 | 16.6 | 1.83 | 3.427 | 3.427 |
| Среднее | | | 181.063 | 52 | 8.3 | 180.313 | 37.5 | 6.5 | 14.5 | 0.75 | | |
| Итого потребление за расчетный месяц | | 888 | 6699.33 | | | 6671.58 | | | | 27.75 | 94.177 | 94.177 |
| Тхв на источнике = 9.00 V гвс (м3) = 0.0 | | | 3629.567 | | | 1622.817 | | | | 6.75 | 22.908 | 22.908 |
| Суммарное время аварийных ситуаций, ч: 0.0 | | | | | | | | | | | | |
| Комментарий: | | | 8328.897 | | | 8294.397 | | | | 24.5 | 117.084 | 117.084 |

Отчет принят
ОРИАТ ПАО "ТГК-1"



/Подпись _____

Отчет сдан: "ООО ""ЖКС № 2 НЕВСКОГО РАЙОНА""

Отчет принят : 2021.11.01 10:58:38
 Комментарии ответственного лица : Принят.