


Отчет (акт) о потреблении тепловой энергии и теплоносителя за период с 16.09.2021 по 22.10.2021

Потребитель: "ООО ""ЖКС № 2 НЕВСКОГО РАЙОНА""
 Адрес: ШЛИССЕЛЬБУРГСКИЙ ПР, Д.5, КОРП.2[2]
 Договор: 31502

Тип прибора: ТВ7-03
 Номер прибора: 12002627
 Схема измерения: СИ-1

| Дата | НС, # | п, ч | M1, т | t1, гр.С | P1, кгс/см2 | M2, т | t2, гр.С | P2, кгс/см2 | t1-t2, гр.С | M1-M2, т | Wсумм, Гкал | Линия ГВС, # |
|---------------------------------------|-------|------|----------|----------|-------------|----------|----------|-------------|-------------|----------|-------------|--------------|
| 16.09.2021 | | 24 | 144.4 | 50.9 | 8.7 | 143.58 | 38.2 | 6.8 | 12.7 | 0.82 | 1.916 | 1.916 |
| 17.09.2021 | | 24 | 144.4 | 50.9 | 8.7 | 143.58 | 38.2 | 6.8 | 12.7 | 0.82 | 1.916 | 1.916 |
| 18.09.2021 | | 24 | 144.4 | 50.9 | 8.7 | 143.58 | 38.2 | 6.8 | 12.7 | 0.82 | 1.916 | 1.916 |
| 19.09.2021 | | 24 | 144.4 | 50.9 | 8.7 | 143.58 | 38.2 | 6.8 | 12.7 | 0.82 | 1.916 | 1.916 |
| 20.09.2021 | | 24 | 144.4 | 50.9 | 8.7 | 143.58 | 38.2 | 6.8 | 12.7 | 0.82 | 1.916 | 1.916 |
| 21.09.2021 | | 24 | 144.4 | 50.9 | 8.7 | 143.58 | 38.2 | 6.8 | 12.7 | 0.82 | 1.916 | 1.916 |
| 22.09.2021 | | 24 | 144.4 | 50.9 | 8.7 | 143.58 | 38.2 | 6.8 | 12.7 | 0.82 | 1.916 | 1.916 |
| 23.09.2021 | | 24 | 144.4 | 50.9 | 8.7 | 143.58 | 38.2 | 6.8 | 12.7 | 0.82 | 1.916 | 1.916 |
| 24.09.2021 | | 24 | 144.4 | 50.9 | 8.7 | 143.58 | 38.2 | 6.8 | 12.7 | 0.82 | 1.916 | 1.916 |
| 25.09.2021 | | 24 | 144.4 | 50.9 | 8.7 | 143.58 | 38.2 | 6.8 | 12.7 | 0.82 | 1.916 | 1.916 |
| 26.09.2021 | | 24 | 144.4 | 50.9 | 8.7 | 143.58 | 38.2 | 6.8 | 12.7 | 0.82 | 1.916 | 1.916 |
| 27.09.2021 | | 24 | 144.4 | 50.9 | 8.7 | 143.58 | 38.2 | 6.8 | 12.7 | 0.82 | 1.916 | 1.916 |
| 28.09.2021 | | 24 | 144.4 | 50.9 | 8.7 | 143.58 | 38.2 | 6.8 | 12.7 | 0.82 | 1.916 | 1.916 |
| 29.09.2021 | | 24 | 144.4 | 50.9 | 8.7 | 143.58 | 38.2 | 6.8 | 12.7 | 0.82 | 1.916 | 1.916 |
| 30.09.2021 | | 24 | 144.4 | 50.9 | 8.7 | 143.58 | 38.2 | 6.8 | 12.7 | 0.82 | 1.916 | 1.916 |
| 01.10.2021 | | 24 | 144.4 | 50.9 | 8.7 | 143.58 | 38.2 | 6.8 | 12.7 | 0.82 | 1.916 | 1.916 |
| 02.10.2021 | | 24 | 144.4 | 50.9 | 8.7 | 143.58 | 38.2 | 6.8 | 12.7 | 0.82 | 1.916 | 1.916 |
| 03.10.2021 | | 24 | 144.4 | 50.9 | 8.7 | 143.58 | 38.2 | 6.8 | 12.7 | 0.82 | 1.916 | 1.916 |
| 04.10.2021 | | 24 | 144.4 | 50.9 | 8.7 | 143.58 | 38.2 | 6.8 | 12.7 | 0.82 | 1.916 | 1.916 |
| 05.10.2021 | | 24 | 144.4 | 50.9 | 8.7 | 143.58 | 38.2 | 6.8 | 12.7 | 0.82 | 1.916 | 1.916 |
| 06.10.2021 | | 24 | 144.4 | 50.9 | 8.7 | 143.58 | 38.2 | 6.8 | 12.7 | 0.82 | 1.916 | 1.916 |
| 07.10.2021 | | 24 | 144.982 | 51.7 | 8.7 | 144.982 | 49.6 | 6.8 | 2 | 0 | 0.295 | 0.295 |
| 08.10.2021 | | 24 | 144.2 | 54.7 | 8.7 | 139.185 | 43.9 | 6.8 | 10.8 | 5.015 | 1.784 | 1.784 |
| 09.10.2021 | | 24 | 154.031 | 45.3 | 8.7 | 154.031 | 33.1 | 6.8 | 12.2 | 0 | 1.885 | 1.885 |
| 10.10.2021 | | 24 | 105.867 | 34.7 | 8.7 | 105.847 | 26.6 | 6.8 | 8 | 0.02 | 0.85 | 0.85 |
| 11.10.2021 | | 24 | 153.276 | 58.3 | 8.7 | 153.276 | 39 | 6.8 | 19.4 | 0 | 2.968 | 2.968 |
| 12.10.2021 | | 24 | 153.393 | 52.2 | 8.7 | 152.854 | 36 | 6.8 | 16.2 | 0.539 | 2.505 | 2.505 |
| 13.10.2021 | | 24 | 155.053 | 59.1 | 8.7 | 154.881 | 39 | 6.8 | 20.1 | 0.171 | 3.125 | 3.125 |
| 14.10.2021 | | 24 | 154.434 | 55.3 | 8.7 | 154.434 | 37.2 | 6.8 | 18.1 | 0 | 2.8 | 2.8 |
| 15.10.2021 | | 24 | 151.732 | 58.2 | 8.7 | 151.732 | 37.8 | 6.8 | 20.3 | 0 | 3.086 | 3.086 |
| 16.10.2021 | | 24 | 150.587 | 58.4 | 8.7 | 150.587 | 38 | 6.8 | 20.4 | 0 | 3.071 | 3.071 |
| 17.10.2021 | | 24 | 150.712 | 57.6 | 8.7 | 150.712 | 37.6 | 6.8 | 20 | 0 | 3.014 | 3.014 |
| 18.10.2021 | | 24 | 150.857 | 57.1 | 8.7 | 150.857 | 37.3 | 6.8 | 19.8 | 0 | 2.983 | 2.983 |
| 19.10.2021 | | 24 | 150.277 | 56.3 | 8.7 | 150.277 | 36.8 | 6.8 | 19.5 | 0 | 2.937 | 2.937 |
| 20.10.2021 | | 24 | 156.665 | 56.2 | 8.7 | 155.397 | 35.6 | 6.8 | 20.6 | 1.268 | 3.273 | 3.273 |
| 21.10.2021 | | 24 | 150.287 | 55.6 | 8.7 | 150.287 | 37 | 6.8 | 18.6 | 0 | 2.788 | 2.788 |
| 22.10.2021 | | 24 | 150.209 | 52.3 | 8.7 | 150.209 | 35.7 | 6.8 | 16.6 | 0 | 2.494 | 2.494 |
| Среднее | | | 146.188 | 52.2 | 8.7 | 145.533 | 37.9 | 6.8 | 14.3 | 0.655 | | |
| Итого потребление за расчетный месяц | | 888 | 5408.964 | | | 5384.731 | | | | 24.233 | 80.095 | 80.095 |
| Тхв на источнике = 9.00 | | | 315.694 | | | 1309.799 | | | | 5.894 | 19.483 | 19.483 |
| Суммарное время аварийных ситуаций, ч | | | 0.0 | | | | | | | | | |
| Комментарий: | | | 6724.658 | | | 6694.53 | | | | 30.127 | 99.578 | 99.578 |

Отчет принят
ОРИАТ ПАО "ТГК-1"



/Подпись _____

Отчет сдан: "ООО ""ЖКС № 2 НЕВСКОГО РАЙОНА""

Отчет принят : 2021.11.01 11:37:30
 Комментарии ответственного лица : Принят.