

Отчет (акт) о потреблении тепловой энергии и теплоносителя за период с 23.03.2022 по 22.04.2022

Потребитель: "ООО ""ЖКС № 2 НЕВСКОГО РАЙОНА""
 Адрес: КАРАВАЕВСКАЯ УЛ, Д.38[1]
 Договор: 31502

Тип прибора: ВКТ-7-04
 Номер прибора: 202704
 Схема измерения: СИ-4

| Дата | НС, # | п, ч | M1, т | t1, гр.С | P1, кгс/см2 | M2, т | t2, гр.С | P2, кгс/см2 | t1-t2, гр.С | M1-M2, т | Wотоп, Гкал | Vгвс, м3 | tгвс, гр.С | Pгвс, кгс/см2 | Wгвс, Гкал | Wсумм, Гкал |
|------------|-------|------|-----------|----------|-------------|-----------|----------|-------------|-------------|----------|-------------|----------|------------|---------------|------------|-------------|
| 23.03.2022 | | 24 | 159.79 | 56.2 | 7.6 | 146.72 | 35.4 | 4.9 | 20.8 | 13.07 | 3.78 | 41.82 | 67.8 | 6.1 | 2.835 | 6.615 |
| 24.03.2022 | | 24 | 159.79 | 57.2 | 7.6 | 146.75 | 35.7 | 4.9 | 21.5 | 13.04 | 3.905 | 42.65 | 67.9 | 6.3 | 2.895 | 6.8 |
| 25.03.2022 | | 24 | 161.99 | 59.9 | 7.6 | 149.08 | 37 | 5 | 22.9 | 12.91 | 4.186 | 38.49 | 67.8 | 5.7 | 2.609 | 6.794 |
| 26.03.2022 | | 24 | 160.44 | 63.9 | 7.6 | 147.95 | 38.1 | 5 | 25.8 | 12.49 | 4.609 | 42.29 | 67.7 | 6.1 | 2.862 | 7.471 |
| 27.03.2022 | | 24 | 157.28 | 68.9 | 7.6 | 144.43 | 39.2 | 5 | 29.8 | 12.85 | 5.187 | 44.16 | 69 | 6.2 | 3.045 | 8.232 |
| 28.03.2022 | | 24 | 161.57 | 68.8 | 7.6 | 148.25 | 39.6 | 5 | 29.2 | 13.32 | 5.242 | 42 | 66.8 | 5.3 | 2.808 | 8.05 |
| 29.03.2022 | | 24 | 160.59 | 70.6 | 7.6 | 153.27 | 40.2 | 4.9 | 30.3 | 7.32 | 5.165 | 39.63 | 65.5 | 6 | 2.594 | 7.759 |
| 30.03.2022 | | 24 | 160.27 | 70 | 7.6 | 158.26 | 40 | 5 | 30.1 | 2.01 | 4.9 | 39.49 | 65.5 | 5.8 | 2.585 | 7.485 |
| 31.03.2022 | | 24 | 161.38 | 68.7 | 7.6 | 159.42 | 40 | 4.9 | 28.8 | 1.96 | 4.718 | 42.03 | 65.4 | 5.4 | 2.75 | 7.468 |
| 01.04.2022 | | 24 | 162.29 | 68.7 | 7.6 | 159.54 | 40.2 | 4.9 | 28.5 | 2.75 | 4.736 | 42.78 | 65.5 | 5.7 | 2.803 | 7.539 |
| 02.04.2022 | | 24 | 162.59 | 68.6 | 7.6 | 154.94 | 40.4 | 5 | 28.2 | 7.65 | 4.894 | 43.3 | 65.7 | 5.9 | 2.846 | 7.739 |
| 03.04.2022 | | 24 | 161.87 | 66.3 | 7.7 | 146.75 | 39.3 | 5 | 27 | 15.12 | 4.962 | 47.07 | 66 | 5.8 | 3.107 | 8.068 |
| 04.04.2022 | | 24 | 162.14 | 64.9 | 7.7 | 146.96 | 38.9 | 5.1 | 26 | 15.18 | 4.809 | 42.19 | 65.7 | 5.3 | 2.773 | 7.582 |
| 05.04.2022 | | 24 | 161.66 | 64.9 | 7.7 | 146.57 | 38.8 | 5 | 26.1 | 15.09 | 4.805 | 42.61 | 65.6 | 6.5 | 2.797 | 7.602 |
| 06.04.2022 | | 24 | 159.69 | 64.9 | 7.7 | 144.6 | 38.4 | 5 | 26.5 | 15.09 | 4.805 | 45.29 | 65.6 | 5.3 | 2.973 | 7.778 |
| 07.04.2022 | | 24 | 158.74 | 59.2 | 7.6 | 143.6 | 36.3 | 5.1 | 22.9 | 15.14 | 4.19 | 40.73 | 65.5 | 5.7 | 2.667 | 6.857 |
| 08.04.2022 | | 24 | 160.7 | 54.5 | 7.6 | 144.84 | 34.9 | 5 | 19.6 | 15.86 | 3.711 | 40.79 | 66.9 | 5.6 | 2.727 | 6.438 |
| 09.04.2022 | | 24 | 158.41 | 52.8 | 7.6 | 142.99 | 33.9 | 5 | 18.9 | 15.42 | 3.513 | 43.12 | 67.8 | 5.9 | 2.921 | 6.434 |
| 10.04.2022 | | 24 | 157.88 | 54.2 | 7.6 | 142.47 | 34.4 | 5.1 | 19.9 | 15.41 | 3.665 | 47.32 | 68.3 | 4.4 | 3.234 | 6.899 |
| 11.04.2022 | | 24 | 158.59 | 53.5 | 7.6 | 143.25 | 34.3 | 5 | 19.2 | 15.34 | 3.567 | 41.02 | 66.6 | 5.7 | 2.734 | 6.3 |
| 12.04.2022 | | 24 | 158.69 | 53.6 | 7.6 | 143.26 | 34.4 | 5.1 | 19.2 | 15.43 | 3.579 | 41.97 | 65.1 | 5.9 | 2.733 | 6.312 |
| 13.04.2022 | | 24 | 158.75 | 54.2 | 7.7 | 150.48 | 34.9 | 5.1 | 19.4 | 8.27 | 3.36 | 43.1 | 65.3 | 5.3 | 2.815 | 6.175 |
| 14.04.2022 | | 24 | 158.38 | 54.2 | 7.7 | 156.26 | 34.9 | 5.1 | 19.4 | 2.12 | 3.142 | 39.38 | 65.6 | 5.7 | 2.583 | 5.725 |
| 15.04.2022 | | 24 | 158.05 | 54.2 | 7.7 | 155.98 | 34.7 | 5.1 | 19.5 | 2.07 | 3.152 | 40.6 | 65.7 | 6.2 | 2.666 | 5.818 |
| 16.04.2022 | | 24 | 157.16 | 54.2 | 7.6 | 155.12 | 34.5 | 5 | 19.7 | 2.04 | 3.17 | 44.89 | 65.7 | 5.8 | 2.95 | 6.119 |
| 17.04.2022 | | 24 | 157.84 | 54 | 7.6 | 155.88 | 34.6 | 5 | 19.3 | 1.96 | 3.119 | 47.19 | 65.6 | 6.4 | 3.094 | 6.213 |
| 18.04.2022 | | 24 | 158.93 | 53.3 | 7.6 | 157.02 | 34.7 | 5.1 | 18.6 | 1.91 | 3.022 | 44.36 | 65.6 | 5.2 | 2.912 | 5.934 |
| 19.04.2022 | | 24 | 159.34 | 53.3 | 7.6 | 157.39 | 34.8 | 5 | 18.6 | 1.95 | 3.024 | 39.64 | 65.7 | 4.9 | 2.606 | 5.629 |
| 20.04.2022 | | 24 | 159.6 | 53.3 | 7.5 | 157.75 | 35 | 5 | 18.3 | 1.85 | 2.989 | 41.23 | 66 | 6.2 | 2.72 | 5.708 |
| 21.04.2022 | | 24 | 161.14 | 53.3 | 7.6 | 159.36 | 35.2 | 4.9 | 18.1 | 1.78 | 2.974 | 44.72 | 65.9 | 5.9 | 2.946 | 5.921 |
| 22.04.2022 | | 24 | 162.5 | 53.3 | 7.6 | 160.77 | 35.5 | 5 | 17.8 | 1.73 | 2.947 | 39.35 | 65.5 | 5.1 | 2.578 | 5.525 |
| Среднее | | | 159.937 | 59.6 | 7.6 | 150.965 | 36.7 | 5 | 22.9 | 8.972 | | 42.426 | 66.3 | 5.7 | | |
| Итого | | 744 | 4958.04 | | | 4679.91 | | | | 278.13 | 123.825 | 1315.21 | | | 87.167 | 210.993 |
| Досчёт | | | 1279.494 | | | 1207.719 | | | | 71.775 | 31.955 | 339.409 | | | 22.495 | 54.45 |
| Снятие | | | -1512.508 | | | -1393.341 | | | | -119.166 | -46.769 | -375.535 | | | -24.733 | -71.503 |
| Сумма | | | 4725.026 | | | 4494.287 | | | | 230.739 | 109.011 | 1279.084 | | | 84.929 | 193.94 |

Итого потребление за расчетный месяц
 Тхв на источнике = 0.90 V гвс (м3) = 0.0 W гвс (Гкал) = 0.0 W без гвс (Гкал) = 0.0
 Суммарное время аварийных ситуаций, ч : 0.0
 Комментарий:

Отчет сдан: "ООО ""ЖКС № 2 НЕВСКОГО РАЙОНА""

Отчет принят : 2022.04.30 12:35:52
 Комментарий ответственного лица : Принят.

Отчет принят
 ОРИАТ ПАО "ТГК-1"

/Подпись _____

