

Отчет (акт) о потреблении тепловой энергии и теплоносителя за период с 23.03.2022 по 22.04.2022

Потребитель: "ООО ""ЖКС № 2 НЕВСКОГО РАЙОНА""
 Адрес: ШЛИССЕЛЬБУРГСКИЙ ПР, Д.21[2]
 Договор: 31502

Тип прибора: ВКТ-7-04
 Номер прибора: 215577
 Схема измерения: СИ-2

| Дата | НС, # | п, ч | M1, т | t1, гр.С | P1, кгс/см2 | M2, т | t2, гр.С | P2, кгс/см2 | t1-t2, гр.С | M1-M2, т | V1гвс, м3 | t1гвс, гр.С | P1гвс, кгс/см2 | Wсумм, Гкал |
|------------|-------|------|-----------|----------|-------------|-----------|----------|-------------|-------------|----------|-----------|-------------|----------------|-------------|
| 23.03.2022 | | 24 | 120.95 | 54.6 | 11.1 | 118.37 | 35.8 | 5.8 | 18.8 | 2.58 | | | | 2.367 |
| 24.03.2022 | | 24 | 120.69 | 55.2 | 9.4 | 118.49 | 36 | 5.8 | 19.2 | 2.2 | | | | 2.398 |
| 25.03.2022 | | 24 | 114.63 | 57.9 | 9.1 | 109.52 | 37.4 | 5.8 | 20.5 | 5.11 | | | | 2.54 |
| 26.03.2022 | | 24 | 119.76 | 61.5 | 12.1 | 116.82 | 38.3 | 5.8 | 23.2 | 2.94 | | | | 2.887 |
| 27.03.2022 | | 24 | 119.32 | 65.2 | 10.2 | 116.4 | 39.1 | 5.8 | 26.1 | 2.92 | | | | 3.23 |
| 28.03.2022 | | 24 | 118.48 | 65.2 | 11.2 | 115.7 | 39.2 | 5.8 | 26 | 2.78 | | | | 3.194 |
| 29.03.2022 | | 24 | 120.27 | 68 | 6.9 | 117.65 | 40.2 | 5.8 | 27.9 | 2.62 | | | | 3.457 |
| 30.03.2022 | | 24 | 119.06 | 69.8 | 3 | 116.86 | 40.7 | 5.8 | 29.1 | 2.2 | | | | 3.559 |
| 31.03.2022 | | 24 | 119.14 | 70.3 | 10 | 117.23 | 40.9 | 5.8 | 29.4 | 1.91 | | | | 3.58 |
| 01.04.2022 | | 24 | 119.24 | 69.7 | 12.1 | 117.46 | 40.8 | 5.8 | 28.9 | 1.78 | | | | 3.519 |
| 02.04.2022 | | 24 | 119.77 | 68.4 | 11.6 | 117.99 | 40.6 | 5.8 | 27.8 | 1.78 | | | | 3.404 |
| 03.04.2022 | | 24 | 119.92 | 67.4 | 8 | 118.13 | 40.2 | 5.8 | 27.1 | 1.79 | | | | 3.327 |
| 04.04.2022 | | 24 | 119.97 | 67 | 10.9 | 118.17 | 40.2 | 5.8 | 26.8 | 1.8 | | | | 3.283 |
| 05.04.2022 | | 24 | 120.02 | 64.5 | 11.6 | 118.19 | 39.2 | 5.8 | 25.3 | 1.83 | | | | 3.108 |
| 06.04.2022 | | 24 | 119.99 | 64.6 | 12 | 118.15 | 39.1 | 5.8 | 25.5 | 1.84 | | | | 3.135 |
| 07.04.2022 | | 24 | 119.97 | 65.8 | 9.4 | 118.13 | 39.6 | 5.8 | 26.1 | 1.84 | | | | 3.208 |
| 08.04.2022 | | 24 | 120.76 | 62.2 | 10.3 | 118.74 | 39 | 5.8 | 23.2 | 2.02 | | | | 2.883 |
| 09.04.2022 | | 24 | 120.81 | 53.4 | 12.1 | 118.81 | 35.2 | 5.8 | 18.1 | 2 | | | | 2.258 |
| 10.04.2022 | | 24 | 120.19 | 56.1 | 13.5 | 118.35 | 36.2 | 5.8 | 19.9 | 1.84 | | | | 2.458 |
| 11.04.2022 | | 24 | 120.1 | 55.2 | 13.5 | 118.27 | 36 | 5.8 | 19.2 | 1.83 | | | | 2.372 |
| 12.04.2022 | | 24 | 119.98 | 53.5 | 7.8 | 118.25 | 35.5 | 5.8 | 18 | 1.73 | | | | 2.219 |
| 13.04.2022 | | 24 | 119.8 | 56.3 | 6.8 | 118.2 | 36.7 | 5.8 | 19.6 | 1.6 | | | | 2.406 |
| 14.04.2022 | | 24 | 119.81 | 54.9 | 2.7 | 118.27 | 36.1 | 5.8 | 18.8 | 1.54 | | | | 2.309 |
| 15.04.2022 | | 24 | 115.1 | 54.4 | 9.1 | 110.63 | 35.8 | 5.8 | 18.7 | 4.47 | | | | 2.311 |
| 16.04.2022 | | 24 | 120.28 | 54.8 | 9.1 | 117.64 | 35.9 | 5.8 | 19 | 2.64 | | | | 2.376 |
| 17.04.2022 | | 24 | 120.31 | 55.2 | 9.1 | 117.75 | 36.1 | 5.8 | 19 | 2.56 | | | | 2.381 |
| 18.04.2022 | | 24 | 120.12 | 53.8 | 9.1 | 117.72 | 35.8 | 5.8 | 18 | 2.4 | | | | 2.249 |
| 19.04.2022 | | 24 | 120.14 | 53.2 | 9.1 | 117.9 | 35.8 | 5.8 | 17.4 | 2.24 | | | | 2.175 |
| 20.04.2022 | | 24 | 120.36 | 52.7 | 9.1 | 118.15 | 35.8 | 5.8 | 16.9 | 2.21 | | | | 2.111 |
| 21.04.2022 | | 24 | 123.34 | 52.3 | 9.1 | 118.04 | 36 | 5.8 | 16.3 | 5.3 | | | | 2.205 |
| 22.04.2022 | | 24 | 109.19 | 52.6 | 9.1 | 104.96 | 36.3 | 5.8 | 16.4 | 4.23 | | | | 1.94 |
| Среднее | | | 119.402 | 59.9 | 9.6 | 116.934 | 37.7 | 5.8 | 22.1 | 2.469 | | | | |
| Итого | | 744 | 3701.47 | | | 3624.94 | | | | 76.53 | | | | 84.848 |
| Досчёт | | | 955.218 | | | 935.468 | | | | 19.75 | | | | 21.896 |
| Снятие | | | -1086.059 | | | -1063.864 | | | | -22.195 | | | | -31.373 |
| Сумма | | | 3570.629 | | | 3496.544 | | | | 74.085 | | | | 75.372 |

Итого потребление за расчетный месяц
 Тхв на источнике = 0.90 V гвс (м3) = 0.0
 Суммарное время аварийных ситуаций, ч : 0.0
 Комментарий:

Отчет сдан: "ООО ""ЖКС № 2 НЕВСКОГО РАЙОНА""

Отчет принят : 2022.04.30 15:27:33
 Комментарий ответственного лица : Принят.

Отчет принят
 ОРИАТ ПАО "ТГК-1"

/Подпись _____

