

Отчет (акт) о потреблении тепловой энергии и теплоносителя за период с 23.10.2022 по 22.11.2022

Потребитель: ООО "ЖКС № 2 НЕВСКОГО РАЙОНА"
 Адрес: ШЛИССЕЛЬБУРГСКИЙ ПР, Д.23, КОРП.1[2]
 Договор: 31502

Тип прибора: ТВ7-01
 Номер прибора: 12001524
 Схема измерения: СИ-1

| Дата | НС, # | п, ч | M1, т | t1, гр.С | P1, кгс/см2 | M2, т | t2, гр.С | P2, кгс/см2 | t1-t2, гр.С | M1-M2, т | Wсумм, Гкал | Линия ГВС, # |
|------------|-------|------|-----------|----------|-------------|-----------|----------|-------------|-------------|----------|-------------|--------------|
| 23.10.2022 | | 24 | 153.51 | 56.7 | 8.8 | 153.51 | 38.5 | 6.5 | 18.2 | 0 | 2.787 | 0 |
| 24.10.2022 | | 24 | 150.72 | 61.5 | 8.8 | 150.72 | 40.2 | 6.5 | 21.3 | 0 | 3.21 | 0 |
| 25.10.2022 | | 24 | 146.16 | 63 | 8.8 | 146.16 | 40.3 | 6.5 | 22.7 | 0 | 3.328 | 0 |
| 26.10.2022 | | 24 | 149.03 | 64.6 | 8.8 | 149.03 | 41.4 | 6.5 | 23.2 | 0 | 3.459 | 0 |
| 27.10.2022 | | 24 | 150.97 | 65.1 | 8.8 | 150.97 | 42.5 | 6.5 | 22.6 | 0 | 3.415 | 0 |
| 28.10.2022 | | 24 | 153.72 | 56.5 | 8.8 | 153.72 | 39.3 | 6.5 | 17.2 | 0 | 2.654 | 0 |
| 29.10.2022 | | 24 | 153.82 | 57.7 | 8.8 | 153.82 | 39.8 | 6.5 | 17.9 | 0 | 2.741 | 0 |
| 30.10.2022 | | 24 | 153.66 | 56.5 | 8.8 | 153.66 | 39 | 6.5 | 17.5 | 0 | 2.696 | 0 |
| 31.10.2022 | | 24 | 152.1 | 60.6 | 8.8 | 152.1 | 39.9 | 6.5 | 20.7 | 0 | 3.153 | 0 |
| 01.11.2022 | | 24 | 151.97 | 61.3 | 8.8 | 151.97 | 40.3 | 6.5 | 21 | 0 | 3.182 | 0 |
| 02.11.2022 | | 24 | 153.56 | 59.3 | 8.8 | 153.56 | 39.6 | 6.5 | 19.7 | 0 | 3.022 | 0 |
| 03.11.2022 | | 24 | 152.98 | 62.8 | 8.8 | 152.98 | 40.9 | 6.5 | 21.9 | 0 | 3.359 | 0 |
| 04.11.2022 | | 24 | 152.08 | 64.2 | 8.8 | 151.98 | 41 | 6.5 | 23.2 | 0.1 | 3.534 | 0 |
| 05.11.2022 | | 24 | 150.2 | 63.5 | 8.8 | 150.2 | 39.8 | 6.5 | 23.7 | 0 | 3.551 | 0 |
| 06.11.2022 | | 24 | 148.51 | 65 | 8.8 | 148.51 | 39.9 | 6.5 | 25.1 | 0 | 3.731 | 0 |
| 07.11.2022 | | 24 | 150.98 | 65 | 8.8 | 150.98 | 40.3 | 6.5 | 24.7 | 0 | 3.721 | 0 |
| 08.11.2022 | | 24 | 154.24 | 59.2 | 8.8 | 154.24 | 38.7 | 6.5 | 20.5 | 0 | 3.157 | 0 |
| 09.11.2022 | | 24 | 154.34 | 54.6 | 8.8 | 154.34 | 37.1 | 6.5 | 17.5 | 0 | 2.711 | 0 |
| 10.11.2022 | | 24 | 154.54 | 54.9 | 8.8 | 154.54 | 37.5 | 6.5 | 17.4 | 0 | 2.687 | 0 |
| 11.11.2022 | | 24 | 171.74 | 55.8 | 8.8 | 169.38 | 37.9 | 6.5 | 17.9 | 2.36 | 3.152 | 0 |
| 12.11.2022 | | 24 | 154.39 | 56.3 | 8.8 | 154.39 | 38.5 | 6.5 | 17.8 | 0 | 2.758 | 0 |
| 13.11.2022 | | 24 | 153.14 | 60.7 | 8.8 | 153.14 | 40.1 | 6.5 | 20.6 | 0 | 3.162 | 0 |
| 14.11.2022 | | 24 | 146.53 | 62.9 | 8.8 | 146.53 | 39.8 | 6.5 | 23.1 | 0 | 3.372 | 0 |
| 15.11.2022 | | 24 | 143.55 | 64.8 | 8.8 | 143.55 | 40 | 6.5 | 24.8 | 0 | 3.557 | 0 |
| 16.11.2022 | | 24 | 142.92 | 68.2 | 8.8 | 142.92 | 40.9 | 6.5 | 27.3 | 0 | 3.906 | 0 |
| 17.11.2022 | | 24 | 146.19 | 69.8 | 8.8 | 146.19 | 41.8 | 6.5 | 28 | 0 | 4.098 | 0 |
| 18.11.2022 | | 24 | 149.08 | 72.2 | 8.8 | 149.08 | 42.5 | 6.5 | 29.7 | 0 | 4.414 | 0 |
| 19.11.2022 | | 24 | 149.63 | 74.7 | 8.8 | 149.63 | 43.1 | 6.5 | 31.6 | 0 | 4.738 | 0 |
| 20.11.2022 | | 24 | 147.94 | 75.1 | 8.8 | 147.94 | 44.5 | 6.5 | 30.6 | 0 | 4.538 | 0 |
| 21.11.2022 | | 24 | 147.17 | 75.9 | 8.8 | 147.17 | 43.7 | 6.5 | 32.2 | 0 | 4.74 | 0 |
| 22.11.2022 | | 24 | 149.96 | 76.6 | 8.8 | 149.87 | 44.5 | 6.5 | 32.1 | 0.09 | 4.804 | 0 |
| Среднее | | | 151.269 | 63.3 | 8.8 | 151.186 | 40.4 | 6.5 | 22.9 | 0.082 | | |
| Итого | | 744 | 4689.33 | | | 4686.78 | | | | 2.55 | 107.336 | 0 |
| Досчёт | | | 1180.446 | | | 1180.343 | | | | 0.103 | 35.7 | 0 |
| Снятие | | | -1312.838 | | | -1301.321 | | | | -11.517 | -23.34 | |
| Сумма | | | 4556.938 | | | 4565.802 | | | | -8.864 | 119.696 | 0 |

Итого потребление за расчетный месяц
 Тхв на источнике = 6.20 V гвс (м3) = 0.0
 Суммарное время аварийных ситуаций, ч : 0.0
 Комментарий:

Отчет сдан: ООО "ЖКС № 2 НЕВСКОГО РАЙОНА"

Отчет принят : 2022.11.28 10:46:35
 Комментарий ответственного лица : Принят.

Отчет принят
 ОРИАТ ПАО "ТГК-1"

/Подпись _____

