

Отчет (акт) о потреблении тепловой энергии и теплоносителя за период с 23.09.2022 по 22.10.2022

Потребитель: "ООО ""ЖКС № 2 НЕВСКОГО РАЙОНА""
 Адрес: УСТИНОВА УЛ, Д.6[3]
 Договор: 31502

Тип прибора: ВКТ-7-02
 Номер прибора: 00044848
 Схема измерения: СИ-1

| Дата | НС, # | п, ч | M1, т | t1, гр.С | P1, кгс/см2 | M2, т | t2, гр.С | P2, кгс/см2 | t1-t2, гр.С | M1-M2, т | Wсумм, Гкал | Линия ГВС, # |
|------------|-------|------|----------|----------|-------------|----------|----------|-------------|-------------|----------|-------------|--------------|
| 23.09.2022 | | 24 | 147.463 | 67.5 | 10.3 | 146.291 | 58.5 | 5.6 | 9 | 1.171 | 1.403 | |
| 24.09.2022 | | 24 | 147.463 | 67.5 | 10.3 | 146.291 | 58.5 | 5.6 | 9 | 1.171 | 1.403 | |
| 25.09.2022 | | 24 | 147.463 | 67.5 | 10.3 | 146.291 | 58.5 | 5.6 | 9 | 1.171 | 1.403 | |
| 26.09.2022 | | 24 | 147.463 | 67.5 | 10.3 | 146.291 | 58.5 | 5.6 | 9 | 1.171 | 1.403 | |
| 27.09.2022 | | 24 | 144.81 | 68.3 | 10.3 | 145.08 | 50.7 | 5.6 | 17.6 | -0.27 | 2.532 | |
| 28.09.2022 | | 24 | 143.36 | 70.2 | 10.3 | 140.91 | 58.6 | 5.6 | 11.6 | 2.45 | 1.802 | |
| 29.09.2022 | | 24 | 142.27 | 69.5 | 10.3 | 137.62 | 63.8 | 5.6 | 5.7 | 4.65 | 1.106 | |
| 30.09.2022 | | 24 | 145.56 | 68.3 | 10.3 | 145.94 | 62.7 | 5.6 | 5.5 | -0.38 | 0.783 | |
| 01.10.2022 | | 24 | 150.55 | 68.6 | 10.3 | 150.6 | 62.9 | 5.6 | 5.7 | -0.05 | 0.855 | |
| 02.10.2022 | | 24 | 143.92 | 67.9 | 10.3 | 143.89 | 62 | 5.6 | 5.9 | 0.03 | 0.845 | |
| 03.10.2022 | | 24 | 161.77 | 59.8 | 10.3 | 160 | 48.6 | 5.6 | 11.2 | 1.77 | 1.895 | |
| 04.10.2022 | | 24 | 169.09 | 51.4 | 10.3 | 168.37 | 35.3 | 5.6 | 16 | 0.72 | 2.739 | |
| 05.10.2022 | | 24 | 162.8 | 52.4 | 10.3 | 159.98 | 34.8 | 5.6 | 17.7 | 2.82 | 2.973 | |
| 06.10.2022 | | 24 | 154.18 | 55.2 | 10.3 | 154.17 | 35.2 | 5.6 | 20 | 0.01 | 3.076 | |
| 07.10.2022 | | 24 | 155.63 | 55.2 | 10.3 | 155.63 | 35.7 | 5.6 | 19.6 | 0 | 3.044 | |
| 08.10.2022 | | 24 | 149.75 | 55.5 | 10.3 | 149.75 | 35.7 | 5.6 | 19.8 | 0 | 2.962 | |
| 09.10.2022 | | 24 | 151.59 | 55.6 | 10.3 | 151.59 | 36 | 5.6 | 19.6 | 0 | 2.979 | |
| 10.10.2022 | | 24 | 149.97 | 55.1 | 10.3 | 149.97 | 35.2 | 5.6 | 19.9 | 0 | 2.986 | |
| 11.10.2022 | | 24 | 147.58 | 54.8 | 10.3 | 147.55 | 34.9 | 5.6 | 19.9 | 0.03 | 2.935 | |
| 12.10.2022 | | 24 | 144.3 | 54.3 | 10.3 | 144.28 | 34.4 | 5.6 | 19.9 | 0.02 | 2.875 | |
| 13.10.2022 | | 24 | 145.37 | 54.1 | 10.3 | 145.33 | 34.1 | 5.6 | 20.1 | 0.04 | 2.919 | |
| 14.10.2022 | | 24 | 142.1 | 54.4 | 10.3 | 142.04 | 34 | 5.6 | 20.4 | 0.06 | 2.905 | |
| 15.10.2022 | | 24 | 143.28 | 54.5 | 10.3 | 143.25 | 34.3 | 5.6 | 20.2 | 0.03 | 2.897 | |
| 16.10.2022 | | 24 | 141.28 | 53.9 | 10.3 | 141.26 | 34 | 5.6 | 19.8 | 0.02 | 2.804 | |
| 17.10.2022 | | 24 | 141.52 | 53.8 | 10.3 | 141.51 | 34 | 5.6 | 19.8 | 0.01 | 2.801 | |
| 18.10.2022 | | 24 | 139.19 | 54.2 | 10.3 | 139.19 | 34 | 5.6 | 20.2 | 0 | 2.805 | |
| 19.10.2022 | | 24 | 132.91 | 55.3 | 10.3 | 132.91 | 33.4 | 5.6 | 21.8 | 0 | 2.904 | |
| 20.10.2022 | | 24 | 134.76 | 58.6 | 10.3 | 134.76 | 34.6 | 5.6 | 24 | 0 | 3.234 | |
| 21.10.2022 | | 24 | 143.88 | 60.5 | 10.3 | 143.88 | 36.5 | 5.6 | 24 | 0 | 3.456 | |
| 22.10.2022 | | 24 | 143.57 | 58.3 | 10.3 | 143.54 | 35.8 | 5.6 | 22.6 | 0.03 | 3.243 | |
| Среднее | | | 147.161 | 59.7 | 10.3 | 146.606 | 43.5 | 5.6 | 16.1 | 0.556 | | |
| Итого | | 720 | 4414.841 | | | 4398.166 | | | | 16.676 | 71.965 | |
| Досчёт | | | 1324.452 | | | 1319.45 | | | | 5.003 | 21.59 | |
| Снятие | | | -144.233 | | | -144.238 | | | | -2.015 | -4.225 | |
| Сумма | | | 5595.061 | | | 5575.397 | | | | 19.664 | 89.33 | |

Итого потребление за расчетный месяц
 Тхв на источнике = 10.40 V гвс (м3) = 0.0
 Суммарное время аварийных ситуаций, ч : 0.0
 Комментарий:

Отчет сдан: "ООО ""ЖКС № 2 НЕВСКОГО РАЙОНА""

Отчет принят : 2022.10.27 10:44:45
 Комментарий ответственного лица : Принят.

Отчет принят
 ОРИАТ ПАО "ТГК-1"

/Подпись _____

