

Отчет (акт) о потреблении тепловой энергии и теплоносителя за период с 23.01.2022 по 22.02.2022

Потребитель: "ООО ""ЖКС № 2 НЕВСКОГО РАЙОНА""
 Адрес: КАРАВАЕВСКАЯ УЛ, Д.38[1]
 Договор: 31502

Тип прибора: ВКТ-7-04
 Номер прибора: 202704
 Схема измерения: СИ-4

| Дата | НС, # | п, ч | M1, т | t1, гр.С | P1, кгс/см2 | M2, т | t2, гр.С | P2, кгс/см2 | t1-t2, гр.С | M1-M2, т | Wотоп, Гкал | Vгвс, м3 | tгвс, гр.С | Pгвс, кгс/см2 | Wгвс, Гкал | Wсумм, Гкал |
|------------|-------|------|-----------|----------|-------------|-----------|----------|-------------|-------------|----------|-------------|----------|------------|---------------|------------|-------------|
| 23.01.2022 | | 24 | 178.43 | 75.7 | 8.2 | 165.8 | 43.4 | 6.6 | 32.3 | 12.63 | 6.31 | 48.87 | 66.5 | 6 | 3.252 | 9.562 |
| 24.01.2022 | | 24 | 178.83 | 73.7 | 8.2 | 166.19 | 42.6 | 6.6 | 31.1 | 12.64 | 6.098 | 42.47 | 66.4 | 5.6 | 2.82 | 8.917 |
| 25.01.2022 | | 24 | 180.47 | 74.6 | 8.2 | 167.92 | 43.4 | 6.5 | 31.3 | 12.55 | 6.189 | 41.52 | 66.3 | 5.5 | 2.753 | 8.942 |
| 26.01.2022 | | 24 | 177.45 | 76.2 | 8.2 | 164.93 | 43.4 | 6.6 | 32.8 | 12.52 | 6.369 | 40.36 | 66.3 | 4.9 | 2.676 | 9.045 |
| 27.01.2022 | | 24 | 177.67 | 75.7 | 8.2 | 165.08 | 43.2 | 6.6 | 32.5 | 12.59 | 6.315 | 41.59 | 66.4 | 4.7 | 2.76 | 9.075 |
| 28.01.2022 | | 24 | 178.8 | 73 | 8.2 | 166.22 | 42.4 | 6.6 | 30.6 | 12.58 | 6.002 | 41.11 | 66.3 | 5.1 | 2.726 | 8.727 |
| 29.01.2022 | | 24 | 178.39 | 73 | 8.2 | 165.77 | 42.3 | 6.6 | 30.7 | 12.62 | 6.009 | 40.98 | 66.3 | 5.8 | 2.717 | 8.726 |
| 30.01.2022 | | 24 | 178.72 | 73 | 8.2 | 165.97 | 42.3 | 6.6 | 30.7 | 12.75 | 6.026 | 48.19 | 66.4 | 5.1 | 3.198 | 9.224 |
| 31.01.2022 | | 24 | 178.57 | 73.3 | 8.2 | 165.75 | 42.5 | 6.5 | 30.8 | 12.82 | 6.052 | 42.44 | 66.2 | 5.1 | 2.808 | 8.859 |
| 01.02.2022 | | 24 | 178.05 | 74 | 8.2 | 165.26 | 42.6 | 6.6 | 31.3 | 12.79 | 6.122 | 40.62 | 66.2 | 5.5 | 2.687 | 8.809 |
| 02.02.2022 | | 24 | 177.65 | 75.2 | 8.2 | 165.01 | 43.1 | 6.5 | 32.1 | 12.64 | 6.252 | 39.89 | 66 | 5.5 | 2.631 | 8.884 |
| 03.02.2022 | | 24 | 176.59 | 78.1 | 8.1 | 163.92 | 43.8 | 6.5 | 34.3 | 12.67 | 6.611 | 41.12 | 66.1 | 5.7 | 2.719 | 9.33 |
| 04.02.2022 | | 24 | 173.46 | 78.8 | 8.1 | 160.7 | 43.2 | 6.6 | 35.6 | 12.76 | 6.735 | 39.2 | 66.1 | 5.7 | 2.591 | 9.325 |
| 05.02.2022 | | 24 | 174.15 | 77 | 8.1 | 161.48 | 42.7 | 6.6 | 34.4 | 12.67 | 6.523 | 41.69 | 66.3 | 5.4 | 2.763 | 9.286 |
| 06.02.2022 | | 24 | 175.69 | 72.1 | 8.1 | 162.3 | 41.4 | 6.5 | 30.6 | 13.39 | 5.933 | 46.05 | 66.5 | 5.9 | 3.064 | 8.997 |
| 07.02.2022 | | 24 | 176.78 | 69.1 | 8.2 | 163.33 | 40.8 | 6.6 | 28.3 | 13.45 | 5.547 | 39.95 | 66.2 | 5.8 | 2.644 | 8.191 |
| 08.02.2022 | | 24 | 177.02 | 69.3 | 8.2 | 163.54 | 41.1 | 6.6 | 28.2 | 13.48 | 5.537 | 38.84 | 66.2 | 5.5 | 2.572 | 8.109 |
| 09.02.2022 | | 24 | 176.88 | 69.5 | 8.1 | 163.34 | 41.2 | 6.5 | 28.3 | 13.54 | 5.565 | 39.2 | 66.1 | 5.6 | 2.59 | 8.155 |
| 10.02.2022 | | 24 | 177.51 | 69 | 8.1 | 163.93 | 41.2 | 6.5 | 27.9 | 13.58 | 5.505 | 39.62 | 65.9 | 5.1 | 2.612 | 8.116 |
| 11.02.2022 | | 24 | 176.75 | 70.3 | 8.1 | 163.16 | 41.5 | 6.5 | 28.7 | 13.59 | 5.644 | 38.51 | 65.9 | 5.2 | 2.536 | 8.181 |
| 12.02.2022 | | 24 | 175.25 | 70.5 | 8.1 | 161.78 | 41.3 | 6.5 | 29.2 | 13.47 | 5.665 | 40.69 | 66 | 5.6 | 2.686 | 8.352 |
| 13.02.2022 | | 24 | 175.65 | 68.7 | 8.1 | 162.22 | 40.9 | 6.5 | 27.8 | 13.43 | 5.441 | 47.42 | 66.3 | 6.1 | 3.143 | 8.584 |
| 14.02.2022 | | 24 | 175.56 | 66.1 | 8 | 162.13 | 39.9 | 6.4 | 26.2 | 13.43 | 5.139 | 45.02 | 66 | 5.5 | 2.97 | 8.109 |
| 15.02.2022 | | 24 | 177.48 | 67 | 8 | 163.92 | 40.5 | 6.5 | 26.5 | 13.56 | 5.26 | 39.64 | 65.8 | 5.5 | 2.61 | 7.87 |
| 16.02.2022 | | 24 | 176.92 | 67 | 8.1 | 163.34 | 40.6 | 6.5 | 26.5 | 13.58 | 5.234 | 41.25 | 65.8 | 5.2 | 2.715 | 7.948 |
| 17.02.2022 | | 24 | 176.76 | 67.4 | 8 | 163.14 | 40.6 | 6.5 | 26.8 | 13.62 | 5.29 | 41 | 65.6 | 5.6 | 2.689 | 7.979 |
| 18.02.2022 | | 24 | 176.32 | 66.8 | 8 | 162.39 | 40.3 | 6.5 | 26.5 | 13.93 | 5.231 | 38.29 | 65.3 | 5.6 | 2.5 | 7.731 |
| 19.02.2022 | | 24 | 177.95 | 67.6 | 8.1 | 164.06 | 40.8 | 6.5 | 26.9 | 13.89 | 5.348 | 41.63 | 65.5 | 5 | 2.728 | 8.076 |
| 20.02.2022 | | 24 | 176.79 | 68.7 | 8.1 | 162.97 | 41 | 6.5 | 27.7 | 13.82 | 5.466 | 47.81 | 65.9 | 4.9 | 3.149 | 8.615 |
| 21.02.2022 | | 24 | 177.74 | 68.8 | 8.1 | 164 | 41.1 | 6.5 | 27.6 | 13.74 | 5.476 | 39.62 | 65.5 | 5.4 | 2.596 | 8.072 |
| 22.02.2022 | | 24 | 178.28 | 70 | 8.1 | 164.42 | 41.7 | 6.5 | 28.3 | 13.86 | 5.619 | 37.93 | 65.5 | 5.6 | 2.484 | 8.103 |
| Среднее | | | 177.179 | 71.6 | 8.1 | 163.999 | 41.8 | 6.5 | 29.8 | 13.18 | | 41.694 | 66.1 | 5.4 | | |
| Итого | | 744 | 5492.56 | | | 5083.97 | | | | 408.59 | 180.511 | 1292.52 | | | 85.386 | 265.897 |
| Досчёт | | | 1063.076 | | | 983.994 | | | | 79.082 | 34.938 | 250.165 | | | 16.526 | 51.464 |
| Снятие | | | -2129.002 | | | -2006.733 | | | | -122.269 | -69.263 | -371.433 | | | -24.586 | -93.849 |
| Сумма | | | 4426.634 | | | 4061.231 | | | | 365.403 | 146.185 | 1171.252 | | | 77.326 | 223.512 |

Итого потребление за расчетный месяц
 Тхв на источнике = 0.20 V гвс (м3) = 0.0 W гвс (Гкал) = 0.0 W без гвс (Гкал) = 0.0
 Суммарное время аварийных ситуаций, ч : 0.0
 Комментарий:

Отчет сдан: "ООО ""ЖКС № 2 НЕВСКОГО РАЙОНА""

Отчет принят : 2022.03.01 16:34:55
 Комментарий ответственного лица : Принят.

Отчет принят
ОРИАТ ПАО "ТГК-1"

/Подпись _____

