

Отчет (акт) о потреблении тепловой энергии и теплоносителя за период с 23.01.2023 по 22.02.2023

Потребитель: ООО "ЖКС № 2 НЕВСКОГО РАЙОНА"
 Адрес: УСТИНОВА УЛ, Д.8[2]
 Договор: 31502

Тип прибора: ВКТ-7-02
 Номер прибора: 42603
 Схема измерения: СИ-1

| Дата | НС, # | п, ч | M1, т | t1, гр.С | P1, кгс/см2 | M2, т | t2, гр.С | P2, кгс/см2 | t1-t2, гр.С | M1-M2, т | Wсумм, Гкал | Линия ГВС, # |
|------------|-------|------|----------|----------|-------------|-----------|----------|-------------|-------------|----------|-------------|--------------|
| 23.01.2023 | | 24 | 119.85 | 74.3 | 10.3 | 119.65 | 43.5 | 5.6 | 30.8 | 0.2 | 3.701 | 0 |
| 24.01.2023 | | 24 | 121.15 | 73.6 | 10.3 | 120.95 | 43.2 | 5.6 | 30.4 | 0.2 | 3.69 | 0 |
| 25.01.2023 | | 24 | 124.51 | 75.3 | 10.3 | 123.49 | 44.5 | 5.6 | 30.8 | 1.02 | 3.873 | 0 |
| 26.01.2023 | | 24 | 129.74 | 77.2 | 10.3 | 128.82 | 46.6 | 5.6 | 30.6 | 0.92 | 4.006 | 0 |
| 27.01.2023 | | 24 | 124.54 | 76.1 | 10.3 | 123.68 | 45.4 | 5.6 | 30.7 | 0.86 | 3.867 | 0 |
| 28.01.2023 | | 24 | 123.35 | 77 | 10.3 | 122.52 | 45.2 | 5.6 | 31.8 | 0.83 | 3.965 | 0 |
| 29.01.2023 | | 24 | 125.29 | 75.9 | 10.3 | 124.3 | 45.4 | 5.6 | 30.5 | 0.99 | 3.869 | 0 |
| 30.01.2023 | | 24 | 120.01 | 73.4 | 10.3 | 118.96 | 44.4 | 5.6 | 29 | 1.05 | 3.535 | 0 |
| 31.01.2023 | | 24 | 117.2 | 73.4 | 10.3 | 116.29 | 43.8 | 5.6 | 29.6 | 0.91 | 3.51 | 0 |
| 01.02.2023 | | 24 | 117.33 | 74.8 | 10.3 | 116.21 | 44.4 | 5.6 | 30.4 | 1.12 | 3.62 | 0 |
| 02.02.2023 | | 24 | 120.8 | 76.3 | 10.3 | 119.77 | 45.5 | 5.6 | 30.8 | 1.03 | 3.769 | 0 |
| 03.02.2023 | | 24 | 122.65 | 79.9 | 10.3 | 121.64 | 47 | 5.6 | 32.9 | 1.01 | 4.085 | 0 |
| 04.02.2023 | | 24 | 123.91 | 82.2 | 10.3 | 122.87 | 48.1 | 5.6 | 34.1 | 1.04 | 4.28 | 0 |
| 05.02.2023 | | 24 | 123.6 | 80.8 | 10.3 | 122.64 | 47.1 | 5.6 | 33.7 | 0.96 | 4.198 | 0 |
| 06.02.2023 | | 24 | 124.89 | 80.9 | 10.3 | 123.87 | 47.6 | 5.6 | 33.3 | 1.02 | 4.2 | 0 |
| 07.02.2023 | | 24 | 124.04 | 79.3 | 10.3 | 123.03 | 47 | 5.6 | 32.3 | 1.01 | 4.059 | 0 |
| 08.02.2023 | | 24 | 123.96 | 75.9 | 10.3 | 122.93 | 45.5 | 5.6 | 30.4 | 1.03 | 3.816 | 0 |
| 09.02.2023 | | 24 | 125.46 | 74.7 | 10.3 | 124.54 | 45.4 | 5.6 | 29.3 | 0.92 | 3.715 | 0 |
| 10.02.2023 | | 24 | 123.39 | 72.8 | 10.3 | 122.35 | 44.3 | 5.6 | 28.5 | 1.04 | 3.559 | 0 |
| 11.02.2023 | | 24 | 121.58 | 73 | 10.3 | 120.56 | 44 | 5.6 | 29 | 1.02 | 3.572 | 0 |
| 12.02.2023 | | 24 | 121.01 | 73.7 | 10.3 | 120.01 | 43.9 | 5.6 | 29.8 | 1 | 3.648 | 0 |
| 13.02.2023 | | 24 | 123.75 | 72.6 | 10.3 | 122.7 | 44.3 | 5.6 | 28.3 | 1.05 | 3.556 | 0 |
| 14.02.2023 | | 24 | 118.07 | 72.7 | 10.3 | 116.21 | 44.2 | 5.6 | 28.5 | 1.86 | 3.45 | 0 |
| 15.02.2023 | | 24 | 124.34 | 73.6 | 10.3 | 124.12 | 44.2 | 5.6 | 29.4 | 0.22 | 3.66 | 0 |
| 16.02.2023 | | 24 | 123.68 | 73.2 | 10.3 | 123.42 | 43.9 | 5.6 | 29.3 | 0.26 | 3.632 | 0 |
| 17.02.2023 | | 24 | 66.06 | 74.5 | 10.3 | 66.11 | 43.7 | 5.6 | 30.8 | -0.05 | 2.034 | 0 |
| 18.02.2023 | | 24 | 76.79 | 77.1 | 10.3 | 76.51 | 43.4 | 5.6 | 33.7 | 0.28 | 2.603 | 0 |
| 19.02.2023 | | 24 | 123.72 | 77.3 | 10.3 | 123.47 | 44.4 | 5.6 | 32.9 | 0.25 | 4.089 | 0 |
| 20.02.2023 | | 24 | 51.51 | 77.5 | 10.3 | 52.29 | 43.5 | 5.6 | 34 | -0.78 | 1.719 | 0 |
| 21.02.2023 | | 24 | 130.05 | 82 | 10.3 | 129.74 | 45.3 | 5.6 | 36.7 | 0.31 | 4.778 | 0 |
| 22.02.2023 | | 24 | 128.19 | 85.5 | 10.3 | 127.91 | 47.6 | 5.6 | 37.9 | 0.28 | 4.87 | 0 |
| Среднее | | | 117.562 | 76.4 | 10.3 | 116.825 | 45.1 | 5.6 | 31.3 | 0.737 | | |
| Итого | | 744 | 3644.42 | | | 3621.56 | | | | 22.86 | 114.93 | 0 |
| Досчёт | | | 600 | | | 599.529 | | | | 0.471 | 20.336 | 0 |
| Снятие | | | -1087.11 | | | -1060.341 | | | | -26.769 | -31.236 | 0 |
| Сумма | | | 3157.31 | | | 3160.748 | | | | -3.438 | 104.03 | 0 |

Итого потребление за расчетный месяц
 Тхв на источнике = 0.20 V гвс (м3) = 0.0
 Суммарное время аварийных ситуаций, ч : 0.0
 Комментарий:

Отчет сдан: ООО "ЖКС № 2 НЕВСКОГО РАЙОНА"

Отчет принят : 2023.02.25 10:05
 Комментарий ответственного лица : Принят.

Отчет принят
 ОРИАТ ПАО "ТГК-1"

/Подпись _____

