

Отчет (акт) о потреблении тепловой энергии и теплоносителя за период с 23.12.2022 по 22.01.2023

Потребитель: ООО "ЖКС № 2 НЕВСКОГО РАЙОНА"
 Адрес: РЫБАЦКИЙ ПР, Д.49, КОРП.1[ОТОП]
 Договор: 31502

Тип прибора: ВКТ-7-02
 Номер прибора: 43740
 Схема измерения: СИ-1

| Дата | НС, # | п, ч | M1, т | t1, гр.С | P1, кгс/см2 | M2, т | t2, гр.С | P2, кгс/см2 | t1-t2, гр.С | M1-M2, т | Wсумм, Гкал | Линия ГВС, # |
|------------|-------|------|-----------|----------|-------------|-----------|----------|-------------|-------------|----------|-------------|--------------|
| 23.12.2022 | | 24 | 122.17 | 70.7 | 10.2 | 122.17 | 47.6 | 5.6 | 23.1 | 0 | 2.829 | 0 |
| 24.12.2022 | | 24 | 121.99 | 74.9 | 10.2 | 121.99 | 49.4 | 5.6 | 25.5 | 0 | 3.103 | 0 |
| 25.12.2022 | | 24 | 121.77 | 79.6 | 10.2 | 121.77 | 51.4 | 5.6 | 28.2 | 0 | 3.439 | 0 |
| 26.12.2022 | | 24 | 121.93 | 83.5 | 10.2 | 121.93 | 53 | 5.6 | 30.5 | 0 | 3.713 | 0 |
| 27.12.2022 | | 24 | 122.23 | 79.7 | 10.2 | 122.23 | 51.4 | 5.6 | 28.3 | 0 | 3.455 | 0 |
| 28.12.2022 | | 24 | 122.51 | 76.7 | 10.2 | 122.51 | 50.2 | 5.6 | 26.5 | 0 | 3.248 | 0 |
| 29.12.2022 | | 24 | 122.35 | 76.4 | 10.2 | 122.35 | 49.9 | 5.6 | 26.5 | 0 | 3.235 | 0 |
| 30.12.2022 | | 24 | 122.84 | 71.6 | 10.2 | 122.84 | 48 | 5.6 | 23.6 | 0 | 2.909 | 0 |
| 31.12.2022 | | 24 | 122.94 | 69.4 | 10.2 | 122.94 | 47 | 5.6 | 22.4 | 0 | 2.76 | 0 |
| 01.01.2023 | | 24 | 122.75 | 71 | 10.2 | 122.75 | 47.7 | 5.6 | 23.3 | 0 | 2.856 | 0 |
| 02.01.2023 | | 24 | 122.48 | 76.5 | 10.2 | 122.48 | 50.1 | 5.6 | 26.4 | 0 | 3.225 | 0 |
| 03.01.2023 | | 24 | 122.23 | 80.4 | 10.2 | 122.23 | 51.7 | 5.6 | 28.7 | 0 | 3.506 | 0 |
| 04.01.2023 | | 24 | 122.35 | 83.4 | 10.2 | 122.35 | 53.1 | 5.6 | 30.3 | 0 | 3.717 | 0 |
| 05.01.2023 | | 24 | 122.08 | 86.5 | 10.2 | 122.08 | 54.1 | 5.6 | 32.4 | 0 | 3.953 | 0 |
| 06.01.2023 | | 24 | 122.3 | 87.2 | 10.2 | 122.3 | 54.3 | 5.6 | 32.9 | 0 | 4.02 | 0 |
| 07.01.2023 | | 24 | 122.17 | 86.3 | 10.2 | 122.17 | 53.8 | 5.6 | 32.5 | 0 | 3.964 | 0 |
| 08.01.2023 | | 24 | 122.34 | 82.9 | 10.2 | 122.34 | 51.4 | 5.6 | 31.5 | 0 | 3.856 | 0 |
| 09.01.2023 | | 24 | 122.41 | 82.3 | 10.2 | 122.36 | 50.9 | 5.6 | 31.4 | 0.05 | 3.843 | 0 |
| 10.01.2023 | | 24 | 122.23 | 82.2 | 10.2 | 122.23 | 50.8 | 5.6 | 31.4 | 0 | 3.839 | 0 |
| 11.01.2023 | | 24 | 121.94 | 79.3 | 10.2 | 121.94 | 50 | 5.6 | 29.3 | 0 | 3.58 | 0 |
| 12.01.2023 | | 24 | 122.12 | 75.3 | 10.2 | 122.12 | 48.2 | 5.6 | 27.1 | 0 | 3.314 | 0 |
| 13.01.2023 | | 24 | 122.44 | 71.1 | 10.2 | 122.44 | 46.5 | 5.6 | 24.6 | 0 | 3.013 | 0 |
| 14.01.2023 | | 24 | 123.01 | 69.4 | 10.2 | 123.01 | 46 | 5.6 | 23.4 | 0 | 2.886 | 0 |
| 15.01.2023 | | 24 | 123.18 | 69.8 | 10.2 | 123.18 | 46.2 | 5.6 | 23.6 | 0 | 2.906 | 0 |
| 16.01.2023 | | 24 | 122.59 | 71.4 | 10.2 | 122.59 | 47.1 | 5.6 | 24.3 | 0 | 2.97 | 0 |
| 17.01.2023 | | 24 | 122.17 | 71.3 | 10.2 | 122.17 | 47.2 | 5.6 | 24.1 | 0 | 2.937 | 0 |
| 18.01.2023 | | 24 | 122.09 | 71.4 | 10.2 | 122.09 | 47.4 | 5.6 | 24 | 0 | 2.934 | 0 |
| 19.01.2023 | | 24 | 122.33 | 71.4 | 10.2 | 122.33 | 47.6 | 5.6 | 23.8 | 0 | 2.914 | 0 |
| 20.01.2023 | | 24 | 121.99 | 71.4 | 10.2 | 121.99 | 47.5 | 5.6 | 23.9 | 0 | 2.916 | 0 |
| 21.01.2023 | | 24 | 121.74 | 75 | 10.2 | 121.74 | 48.9 | 5.6 | 26.1 | 0 | 3.181 | 0 |
| 22.01.2023 | | 24 | 121.39 | 77.3 | 10.2 | 121.39 | 49.8 | 5.6 | 27.5 | 0 | 3.343 | 0 |
| Среднее | | | 122.292 | 76.6 | 10.2 | 122.291 | 49.6 | 5.6 | 27 | 0.002 | | |
| Итого | | 744 | 3791.06 | | | 3791.01 | | | | 0.05 | 102.364 | 0 |
| Досчёт | | | 1098.386 | | | 1098.386 | | | | 0 | 27.25 | 0 |
| Снятие | | | -1427.156 | | | -1427.156 | | | | 0 | -33.9 | 0 |
| Сумма | | | 3462.29 | | | 3462.24 | | | | 0.05 | 95.714 | 0 |

Итого потребление за расчетный месяц
 Тхв на источнике = 0.20 V гвс (м3) = 0.0
 Суммарное время аварийных ситуаций, ч : 0.0
 Комментарий:

Отчет сдан: ООО "ЖКС № 2 НЕВСКОГО РАЙОНА"

Отчет принят : 2023.01.28 18:21
 Комментарий ответственного лица : Принят.

Отчет принят
 ОРИАТ ПАО "ТГК-1"

/Подпись _____

